

# Certificate




for European Product Safety

Reference No. 1125486

## Circuit-breakers with overcurrent protection

Type designation	HDB6L
Certificate holder	<b>Delixi Electric Ltd.</b> <b>Delixi High Tech Industrial Park, Liushi Town, Yueqing City</b> <b>Zhejiang Province, 325604</b> <b>CHINA</b>
The product complies with the standard(s)	EN 60898-1:2003 and A1+A11+A12
Date of expiry	21 December 2016
EU Directive information	<i>The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.</i>

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Bo Berglöv	Date	21 December 2011 Page 1 of 2


*This certificate is issued in accordance with the terms and conditions set out in the Appendix.*



**Intertek  
Appendix**

Reference No. 1125486

*Technical data*

Type designation	HDB6L
Rated voltage (V)	$U_e = 230/400V\sim(1P), 400V\sim(2P, 3P, 4P)$
Rated current (A)	$I_n = 1, 2, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A$ B-,C-,D- Type
Frequency (Hz)	50/60Hz
IP-Class	20
BRAND name:	
Product information	Icn= Ics : 4,5kA

*Manufacturing site(s)* Delixi Electric Ltd.  
Delixi High Tech Industrial Park, Liushi Town, Yueqing City  
Zhejiang Province, 325604, CHINA

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

*Certification Body* Intertek Semko AB, Product Certification *Place* Kista - Stockholm

*Signed*   
Bo Berglöf *Date* 21 December 2011

*This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.*