



CB TEST CERTIFICATE

Ref. Certificate No.

NL-22275

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Circuit-breaker for overcurrent protection		
Applicant:	DELIXI ELECTRIC LTD	Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, 325604	China
Manufacturer:	Delixi Electric (Ningbo) Co., Ltd.	No.1958 Jiangnan Road, National Hi-tech Industrial Development Zone, Ningbo, Zhejiang Province, 315040	China
Factory:	Delixi Electric (Ningbo) Co., Ltd.	No.1958 Jiangnan Road, National Hi-tech Industrial Development Zone, Ningbo, Zhejiang Province, 315040	China
Rating and principal characteristics:	Ue: 230 / 400 Vac (1P), 400 Vac (2P, 3P, 4P) In: 1 A, 2 A, 3 A, 4 A, 5 A, 6 A, 8 A, 10 A, 13 A, 15 A, 16 A, 20 A, 25 A, 32 A, 40 A, 50 A, 63 A B, C, D type, Ambient temperature: 30 °C Uimp: 4 kV, All poles protected Icn = Ics: 4,5 kA Safety distance: 50 mm		
Trade mark (if any):	Himel		
Model/Type reference:	CDB6s		
Additional information:	Energy limiting class 1 This CB certificate is based on CB NL-17108 issued on 2009-11-12		
Sample of product tested to be in conformity with IEC:	60898-1(ed.1);am1;am2		
Test Report Ref. No:	3302792.52, 3302793.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2011-12-19



DEKRA Certification is former KEMA Quality