

ATTESTATION OF CONFORMITY

Issued to: DELIXI ELECTRIC LTD
Delixi High Tech Industrial park, Liushi Town Yueqing City
Zhejiang Province, China 325604

For the product: Circuit breaker for overcurrent protection

Trade name: Himel

Type/Model: HDB6s

Ratings: Ue: 230/400 V (1P), 400 V (2P, 3P, 4P)
In: 1 A, 2 A, 3 A, 4 A, 5 A, 6 A, 8 A, 10 A, 13 A, 15 A, 16 A, 20 A, 25 A, 32 A,
40 A, 50 A, 63 A, B, C, D type
Icn = Ics: 4,5 kA, Uimp: 4 kV, all poles protected
Safety distance: 50 mm
Energy limiting class 1

Manufactured by: Delixi Electric (Ningbo) Co., Ltd.
No.1958 Jiangnan Road, National Hi-tech Industrial Development Zone, Ningbo
Zhejiang Province, China 315040

Subject: Type test

Requirements: EN 60898-1:2003 + A1:2004 + A11:2005 + A12:2008
IEC 60898-1:2002 + A1:2002 + A2:2003

Remark: This AOC is based on 2130181.01AOC issued on 2009-11-09.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3302792.52 and 3302793.50.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 19 December 2011

Number: 2149931.03AOC

DEKRA Certification B.V.



H.R.M. Barends
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.